
from: **Ghali, Ghassan (MOECC)** <Ghassan.Ghali@ontario.ca>

to: "james.dan.lorenzen@gmail.com"
<james.dan.lorenzen@gmail.com>

date: Thu, Mar 8, 2018 at 9:40 AM

subject: FW: Use of Sodium Silicate in Drinking
Water pipe systems for corrosion
prevention and water constituent
management

mailed-
by: ontario.ca

Ghali, Ghassan (MOECC) <Ghassan.Ghali@ontario.ca>
to me

Hello James,

NSF/ANSI 60 certification is required for chemicals used for drinking water treatment. As long as N Sodium Silicate is NSF certified and it's on the NSF list of certified products, it can be used in the water treatment considering any other applicable regulatory conditions, the water system licence, permit or certificate of approval.

Any other question, I can be reached by email or phone.

Regards,

Ghassan Ghali, M.Sc., P. Eng.
Senior Water Engineer
Approvals and Licensing Section
Environmental Assessment and Permissions Branch
Ontario Ministry of the Environment and Climate Change
40 St. Clair Avenue West, 2nd Floor
Toronto ON M4V 1M2
Tel: (416) 314-7652
Fax: (416) 212-7576